



## ARGB – KVBG

The ARGB-KVBG laboratory certifies the conformity with Belgian requirements for gas press fittings.  
*Le laboratoire de l'ARGB certifie que les raccords à sertissage gaz sont conformes aux exigences Belges.*

Het laboratorium van de KVBG verklaart dat de gas persfittings conform zijn aan de Belgische eisen.

Certificate Number : **C-15-3698-A**  
N° du certificat :  
Certificaat nummer :

Date of issue : **09/02/2015**  
Date d'édition :  
Datum van aflevering :

Manufacturer : **SANHA GmbH & Co KG**  
Fabricant : **Im Teelbruch 80**  
Fabrikant : **D- 45219 Essen**

Distributor :  
Distributeur : /  
Verdeler:

Type: **NiroSan (Serie 17000)**  
Stainless steel gas press fittings for stainless steel pipes  
(according to EN 10312)  
*Raccords à sertissage en acier inoxydable pour tuyaux en acier inoxydable*  
(conforme à EN 10312)  
Roestvast stalen gas persfittings voor roestvast stalen buizen  
(volgens EN 10312)  
**MOP: 5 bar - GT: 5 bar**  
**Diameter: 15 – 18 – 22 – 28 – 35 – 42 – 54 mm**  
**Thread EN 10226-1 R/R<sub>p</sub>: 1/2" – 3/4" – 1" – 5/4" – 6/4" – 2"**  
**DN: 15 – 20 – 25 – 32 – 40 - 50**

**Model 17001A**

90° bend, female end/male plain end

**Model 17002A**

90° bend, female/female end

**Model 17002AG**

90° bend, female end and male thread

**Model 17002G**

90° bend, female end and female thread

**Model 17040**

45° bend, female end/male plain end

**Model 17041**

45° bend, female/female end

**Model 17090IG**

Elbow 90°, female end and female thread

**Model 17092AG**

Elbow 90°, female end and male thread

**Model 17130**

Tee, female ends

**Model 17130G**

Tee, with female thread and female/female end

**Model 17243**

Fitting reducer, with female and male plain end

**Model 17243G**

Transition nipple, with female end and male thread

**Model 17270**

Coupling, female/female end

**Model 17270G**

Transition coupling, with female end and female thread

**Model 17270S**

Slip coupling, female/female end

**Model 17301**

Cap, female end

**Model 17472G**

Wall plate with universal flange with female end and female thread

**Model 17-VA-PF**

Crimping flange PN5 with female end

Scope :  
Domaine d'application :  
Toepassingsgebied :

- Low and medium pressure gas installations according to the standards NBN D51-003 and NBN D51-004
- *Installations basse et moyenne pression suivant les normes NBN D51-003 et NBN D51-004*
- Lage en midden druk gasinstallaties volgens de normen NBN D51-003 en NBN D51-004

Ø stainless steel pipe Ø tuyau acier inoxydable Ø roestvast stalen buis	15	18	22	28	35	42	54
Minimum wall thickness stainless steel pipe Epaisseur de paroi minimale du tuyau en inox Minimum wanddikte roestvast stalen buis	1	1	1,2	1,2	1,5	1,5	1,5

Requirements:  
Exigences :  
Eisen :

DVGW G 5614 'Unlösbare Rohrverbindungen für metallene Gasleitungen; Pressverbinder'

DVGW Certificate – nr. DG-4550BP0188 (18.03.2013)  
 MPA NRW Prüfbericht – nr. 120001960 (18.12.2003)  
 MPA NRW Prüfbericht – nr. 120002550/120002550-1/120002550-2 (23.01.2006)

Kenny VANLANCKER  
Laboratory Manager.