



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8511AU2076

Registration Number
Registriernummer

Field of Application
Anwendungsbereich

products of water supply
Produkte der Wasserversorgung

Owner of Certificate
Zertifikatinhaber

SANHA GmbH & Co. KG
Im Teelbruch 80, D-45219 Essen

Distributor
Vertreiber

SANHA GmbH & Co. KG
Im Teelbruch 80, D-45219 Essen

Product Category
Produktart

Installation systems and system joints (PN 10): pipe joint for pipes in drinking water installation systems (8511)

Product description
Produktbezeichnung

compression- and transition fittings made of copper, type M-MM, for copper pipes acc. to DVGW GW 392, unpressed leaky up to diameter 54 mm

Model
Modell

SANHA® Press S6000

Test reports
Prüfberichte

Laboratory control test: 1200000515-22-IB from 22.02.2023 (MPM)
Mechanical test: 120002507-09 from 21.04.2009 (MPM)
UBA Guideline/BWGL: KA 0215/14 from 22.09.2021 (TZW)
Hygienic testing: MO 174/20 from 06.11.2020 (TZW)

Test basis
Prüfgrundlagen

DVGW W 534-(P) (01.07.2015)
DVGW CERT ZP 1000 (20.04.2022)
UBA ELASTOM (16.03.2016)
DVGW W 270 (01.11.2007)

Date of Expiry / File No. 11.03.2029 / 24-0092-WNV
Ablaufdatum / Aktenzeichen

08.05.2024 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com