

SWEDISH TYPE APPROVAL 0275 WITH DECISION ON PRODUCTION CONTROL

Holder: SANHA GmbH & Co. KG

Im Teelbruch 80, 45219 Essen, Germany

Phone: +49 2054 / 925-0

E-mail: info@sanha.com

Web: www.sanha.com

Piping system for water supply

Product description

The pipe system consists of NiroSan® press fittings with an EPDM moulded sealing ring and NiroSan® pipes in stainless steel. The pipe system is made of stainless steel type 1.4404/AISI 316L and is made pressable with press jaw specified by the manufacture

Intended use

System for distribution of hot and cold tap water within a property where the highest operating pressure does not exceed 1.0 MPa and where the water temperature momentarily does not exceed 95°C or continuously does not exceed 70°C.

Scope

NiroSan® series 9000, dimensions: 15x1.0, 18x1.0, 22x1.2, 28x1.2, 35x1.5, 42x1.5, 54x1.5, 64x2.0, 76.1x2.0, 88.9x2.0, 108x2.0 mm.

Approval

The products meet the requirements of Chapter 8, Section 4, of the Planning and Building Act (PBA) regarding the technical characteristics of construction works, specifically protection regarding hygiene, health and the environment as well as the Planning and Building Ordinance (PBO), Chapter 4, Sections 12 and 13, provided that the conditions stated in this approval are followed.

The products are approved in accordance with the following section(s) of "Boverkets Building Regulations" (BBR 29)¹⁾:

Construction products with assessed properties	1:4
Tap water installations	6:62
Design	6:25

The products are approved in accordance with the following sections of Boverket's regulations regarding protection for hygiene, health and environment, as well as the management of water and waste (BFS 2024:8):

General	Chapter 1, Sections 6-7
Water- and waste-water installation	Chapter 8, Sections 1, 3-4 and 6

The regulations in Chapter 8, Section 13 shall always be taken into account during installation.

¹⁾ BBR 29 may be used under the conditions specified in BBR 31.

Kiwa Certification AB

Campus Gräsvik 1
SE-371 75 Karlskrona
Sweden

Tel +46 (0)455-30 56 00

Fax +46 (0)455-104 36

se.bygg@kiwa.com

www.kiwa.se



Accred. no. 1913
Certification of
Products
ISO/IEC 17065