

SVGW

Association
for water, gas and district heating
Grütlistrasse 44
CH- 8027 Zürich

Certification body water



Certificate No.: 9912-4179

Certificate holder: SANHA GmbH & Co. KG
Im Teelbruch 80, DE-45219 Essen

In accordance with our regulation ZW101 „general terms and conditions of the SVGW certification body water“ the SVGW certify the following serial products:

Rubric: Drinking water distribution Systems with metal pipes

Denomination: Press-System „NiroSan“

Types: made up of:
Press fittings system „NiroSan Seri 9000“, made of material 1.4404 or 1.4408
(dn 15, 18, 22, 28, 35, 42, 54, 76, 88.9, 108)
System pipes „NiroSan Series 9000“, made of austenitic steel 1.4404
dn 15 x 1.0, 18 x 1.0, 22 x 1.2, 28 x 1.2, 35 x 1.5, 42 x 1.5, 54 x 1.5, 76.1 x 2.0,
88.9 x 2.0, 108 x 2.0
System pipes „NiroSan-F Series 9700“, made of ferritic steel 1.4521
dn 15 x 1.0, 18 x 1.0, 22 x 1.2, 28 x 1.2, 35 x 1.5, 42 x 1.5, 54 x 1.5, 76.1 x 2.0,
88.9 x 2.0, 108 x 2.0
The certified pipe and press fitting types can be seen on the second certificate
page.

DN: 15...108 PN: 10 tmax: 70 °C

Certification Standard: SVGW ZW132/1 (07/23), DVGW W534 (2015)

Validity: 31.03.2030

Conditions (C) / Remarks (R):

- (A) For ferritic pipes made of material 1.4521, the system binding applies; the system pipes „NiroSan-F Series 9700“ must be used.
- (B) The system tests were carried out with pipes made of 1.4404 and 1.4521 from NiroSan Edelstahlrohr GmbH

The applicant is entitled to offer the above mentioned products as certificated by the SVGW and to use the above SVGW-conformity mark (publication in the list of certificates water).

SVGW Association for water, gas and district heating
Certification body water

Javier Fernandez
Head

Zurich, 22.07.2025